

PASS CERTIFICATE

Testing Address

Printed 23rd April 2010

Testing Carried Out By

THE CASINO BAND

 AVP
 28 RUTLAND STREET
 SWINTON
 MANCHESTER
 M27 0RW

Account Ref: 13713-0499-0000



LOCATION	APP ID	APPLIANCE DESCRIPTION	DATE TESTED	RETEST DUE	VISUAL CHECK	EARTH Ohm	INSUL'N M Ohm	POLARITY CHECK	STATUS
TRANSIT									
	1	MACKIE SW1801A	23/04/10	22/04/11	P	0.16 P	*50.0 P	S	PASS
	2	MACKIE SW1801Z	23/04/10	22/04/11	P	0.18 P	*50.0 P	S	PASS
	3	MACKIE SW1530Z	23/04/10	22/04/11	P	0.15 P	*50.0 P	S	PASS
	4	MACKIE SW1530Z	23/04/10	22/04/11	P	0.15 P	*50.0 P	S	PASS
	5	MACKIE SRM350	23/04/10	22/04/11	P	0.16 P	*50.0 P	S	PASS
	6	XEROX MONITOR	23/04/10	22/04/11	P	0.18 P	*50.0 P	S	PASS
	7	YAMAHA O1V	23/04/10	22/04/11	P	0.16 P	*50.0 P	P	PASS
	8	YAMAHA 02R	23/04/10	22/04/11	P	0.10 P	*50.0 P	P	PASS
	9	CARILLON AC1	23/04/10	22/04/11	P	0.00 P	*50.0 P	S	PASS
	10	MOTU 828	23/04/10	22/04/11	P	0.11 P	*50.0 P	S	PASS
	11	SONY MDS	23/04/10	22/04/11	P	0.11 P	*50.0 P	P	PASS
	12	KORG TRINITY	23/04/10	22/04/11	P	0.15 P	*50.0 P	S	PASS
	13	ROLAND RD500S	23/04/10	22/04/11	P	0.16 P	*50.0 P	S	PASS
	14	I COLOUR 4	23/04/10	22/04/11	P	0.16 P	*50.0 P	P	PASS
	15	I COLOUR 4	23/04/10	22/04/11	P	0.18 P	*50.0 P	P	PASS
	16	MAGIC GOBO	23/04/10	22/04/11	P	0.10 P	*50.0 P	P	PASS
	17	SENNHEISER 300	23/04/10	22/04/11	P	0.07 P	*50.0 P	S	PASS
	18	BEHRINGER 300	23/04/10	22/04/11	P	0.15 P	*50.0 P	S	PASS
	19	PEAVEY 800	23/04/10	22/04/11	P	0.12 P	*50.0 P	S	PASS
	20	EXT 8	23/04/10	22/04/11	P	0.18 P	*50.0 P	P	PASS
	21	EXT 6	23/04/10	22/04/11	P	0.16 P	*50.0 P	P	PASS
	22	EXT 4	23/04/10	22/04/11	P	0.06 P	*50.0 P	P	PASS
	23	EXT 4	23/04/10	22/04/11	P	0.13 P	*50.0 P	P	PASS
	24	EXT 4	23/04/10	22/04/11	P	0.12 P	*50.0 P	P	PASS
	25	EXT 4	23/04/10	22/04/11	P	0.18 P	*50.0 P	P	PASS
	26	EXT 4	23/04/10	22/04/11	P	0.10 P	*50.0 P	P	PASS
	27	EXT 4	23/04/10	22/04/11	P	0.11 P	*50.0 P	P	PASS
	28	EXT 4	23/04/10	22/04/11	P	0.11 P	*50.0 P	P	PASS
	29	EXT 2	23/04/10	22/04/11	P	0.14 P	*50.0 P	P	PASS
	30	EXT 2	23/04/10	22/04/11	P	0.17 P	*50.0 P	P	PASS
	31	EXT 2	23/04/10	22/04/11	P	0.06 P	*50.0 P	P	PASS
	32	EXT 2	23/04/10	22/04/11	P	0.14 P	*50.0 P	P	PASS
	33	EXT 2	23/04/10	22/04/11	P	0.11 P	*50.0 P	P	PASS
	34	EXT 1	23/04/10	22/04/11	P	0.18 P	*50.0 P	P	PASS
	35	EXT 1	23/04/10	22/04/11	P	0.16 P	*50.0 P	P	PASS
	36	PLUG TO IEC	23/04/10	22/04/11	P	0.17 P	*50.0 P	P	PASS
	37	PLUG TO IEC	23/04/10	22/04/11	P	0.11 P	*50.0 P	P	PASS
	38	PLUG TO IEC	23/04/10	22/04/11	P	0.00 P	*50.0 P	P	PASS
	39	PLUG TO IEC	23/04/10	22/04/11	P	0.18 P	*50.0 P	P	PASS
	40	PLUG TO IEC	23/04/10	22/04/11	P	0.13 P	*50.0 P	P	PASS
	41	PLUG TO IEC	23/04/10	22/04/11	P	0.12 P	*50.0 P	P	PASS
	42	PLUG TO IEC	23/04/10	22/04/11	P	0.17 P	*50.0 P	P	PASS
	43	PLUG TO IEC	23/04/10	22/04/11	P	0.00 P	*50.0 P	P	PASS
	44	PLUG TO IEC	23/04/10	22/04/11	P	0.11 P	*50.0 P	P	PASS
	45	PLUG TO IEC	23/04/10	22/04/11	P	0.12 P	*50.0 P	P	PASS
	46	PLUG TO IEC	23/04/10	22/04/11	P	0.11 P	*50.0 P	P	PASS
	47	PLUG TO IEC	23/04/10	22/04/11	P	0.16 P	*50.0 P	P	PASS
	48	PLUG TO IEC	23/04/10	22/04/11	P	0.09 P	*50.0 P	P	PASS

TOTAL APPLIANCES TESTED 48

TEST ENGINEER.....

DATE 23/4/10.....